



BH-400/401
BUILDING HEATERS
 SIZE: 12,000 BTU/h CATADYNE
 c/w GRILL GUARD, SAFETY SHUTOFF, 912
 REGULATOR, THERMOSTAT, 30" OF
 120 VOLT WIRED TO JUNCTION BOX, VENT HOOD
 O/S SWEET NATURAL GAS

V-100
3 PHASE HORIZONTAL SEPARATOR
 SIZE: 64" ID x 18'-0" S/S
 DESIGN PRESS.: 740 PSIG @ 100°F
 CORROSION ALLOWANCE: 1/16"
 X-RAY: RT-1
 MDMT: -20°F
 REGISTERED IN AB & BC
 DESIGNED AND DRESSED 3 PHASE

REFERENCE DRAWINGS	
DWG. NO.	TITLE

NO.	DATE	REVISIONS	DWN BY	CHK'D BY	APPR BY
A	02.04.10	ISSUED FOR APPROVAL			
1	02.05.22	ISSUED FOR PHASE 1 CONSTRUCTION	C.M.	DT	CS
2	02.09.18	ISSUED FOR HAZOP - PHASE II (VECO #4523)	W.W.		
3	02.10.10	ISSUED FOR BID - PHASE II (VECO #4523)	W.W.		
4	02.10.30	ISSUED FOR CONSTRUCTION - PHASE II (VECO #4523)	W.W.	DT	CS

PERMIT
 PERMIT TO PRACTICE
 ALBERTA No. P6361

SEAL

RELEASED ONLY FOR			DATE:
SECT. LEADER	PROJ. ENG.	DATE	02.04.03
CHECKING			SCALE: NTS
PRELM.			DESIGN: DT
BIDDING			DRAWN: C.M.
FABRIC.			CHKD: DT
CONSTR.			APP.: CS

CONOCO CONOCO CANADA RESOURCES LIMITED
VECO CANADA LTD.
 Alliance Group

LAPP (OIL) BATTERY
 LSD b-30-C / 94-H-10
 P & ID OIL GROUP SEPARATOR

LAPP CAD NO. LAP-BAT-PID-0012
 CONTRACTOR PROJ. NO. 4523

SIZE DWG. NO. REV.
 D LAP-BAT-PID-0012 4